

BUILDING DIVISION

PLAN CHECK NOTE

From: Building Plan Check

PCN #27

Date: 2-11-2010

Subject: Code requirements for Walk-in refrigerators and freezers

Code reference:

2007 California Building Code, 2008 California Energy Standards

Purpose:

Provide a compilation of code requirements of concern for site built structures used as walk-in refrigerators and freezer.

Findings:

1. Exiting

- a. CBC 1008.1.1 limits exit doors to 4' wide. However, since 1008.1.2 allows overhead and sliding doors for spaces with an occupant load of 10 or less, swing doors larger than 4' wide can be approved since they are also limited to the opening forces to meet accessibility.
- b. CBC 1015.5 requires two exits for spaces 1000 sq ft or more, but with exceptions.

2. Accessibility

Per CBC 1114B.1.2 and 1110B.2.2, an accessible path of travel is required into the walk-in refrigerator and freezer. This includes landing sizes, ramps, thresholds, door opening force, door hardware and at least one 3' door providing a 32" clear width. Per 1133B.2.2, doors as small as 20" are allowed when passage is not required, as for reach in units.

3. Structural

Structural calculations and plans are required. The Panels used must be HCD approved, have a current ICC report, or other similar recognized third party approval.

4. Energy efficiency

- a. Walk-in refrigerators and freezers **3000 sq ft or larger** per section 126 of the 2008 energy standards, mandatory requirements for refrigerated warehouses:

Refrigerator walls and ceilings:	R-28 min.
Freezer walls, ceilings, and floors:	R-36 min.

- b. Walk-in refrigerators or freezers **under 3000 sq ft** per section 1605.1 (a) of the California Appliance Efficiency Standards, (see <http://www.energy.ca.gov/2009publications/CEC-400-2009-013/CEC-400-2009-013.PDF>):

Refrigerator walls, ceilings and doors:	R-25 min.
Freezer walls, ceilings and doors:	R-32 min.
Freezer floors:	R-28 min.

- c. Strip or self closing doors are required. Glass for doors and windows shall be double pane for refrigerators, and triple pane for freezers.
- d. As written, The Federal Energy Independence and Security Act of 2007, section 312, supersedes any California regulation issued prior to 2011 under title 20. The current California Appliance Efficiency Standards applies to products manufactured after Jan 1, 2009 and regulates appliances beyond those covered by the Federal act. Both are the same for walk-in refrigerators and freezers at this time.

5. **Mechanical Code** The mechanical plans must identify if the cooler and freezer rooms meet CMC 1105.2 and 1105.3.

6. **Fire Code** In sprinklered buildings, the sprinklers shall be extended to the walk-in refrigerator or freezer with corrosion resistant heads.