

SAN JOSE FIRE DEPARTMENT

Emergency Equipment Testing Record Information

San Jose Fire Department Binder:

The San Jose Fire Department requires testing of all emergency equipment. Records of all tests and inspections shall be maintained in a “RED” binder labeled “SJFD” and stored on the premises for review by the fire department official when requested. Depending on your building features, some, or all of the following may apply:

- ❑ Fire Alarm written contract with certified personnel for the testing of the Fire Alarm System: NFPA 72
- ❑ Fire Alarm System annual test document with completion date: NFPA 72
- ❑ Fire Fighter’s telephone system annual test. NFPA. Title-19
- ❑ Automatic Fire Sprinkler Five year certification test date: Title-19
- ❑ Automatic Fire Sprinkler system quarterly maintenance and service: Title 19
- ❑ Standpipe semi-annual maintenance and service: Title-19
- ❑ Emergency Generator monthly test: NFPA 110
- ❑ Fire Pump Monthly test for diesel and electrical driven system. Annual flow test: NFPA 25
- ❑ Exit and Emergency Lighting Monthly test: NFPA 101
- ❑ Elevator monthly test and Elevator emergency devices: NFPA 101
- ❑ Fire Door Annual inspection and test: NFPA 92A
- ❑ Annual Fire Evacuation Drill and report: Title-19
- ❑ Facility Emergency Evacuation Manual: Title-19
- ❑ Fire Safety Director and Employee training records. Title-19
- ❑ Hazardous Materials Business Plans with certification date: Title-19