



## **Fire Apparatus Access Road**

CBC 2022 Section 503 and Appendix D

Curbs for roadways not exceeding the minimum width requirements, and curbs for Dead-ends, are required to be painted red.

D103.3 Turning radius. The minimum required inner turning radius shall be 30 feet and the minimum required outer turning radius shall be 50 feet. These turning radii shall apply to Appendix D Figure D103.1 (Dead-End Fire Apparatus Access Road Turnaround)

D103.5 Fire apparatus access road gates. Gates securing the fire apparatus access roads shall comply with all of the following criteria: 1. Where a single gate is provided, the gate width shall be not less than 20 feet (6096 mm). Where a fire apparatus road consists of a divided roadway, the gate width shall be not less than 14 feet.

2022 CFC D105.1 amended per SJMC 17.12 Part 13  
Exception deleted.