



# Recycled Water Inspection Checklist: Cooling Tower

3025 Tuers Road San Jose, CA 95121 408-277-3671 www.sanjoeca.gov/sbwr

P  
 \_\_\_\_\_  
 XXX    ####    X    MOD#  
 PROJECT ID

<b>USE CLASS</b>	INDUSTRIAL
------------------	------------

<b>SITE LOCATION &amp; SITE SUPERVISOR</b>	<hr/> SITE NAME
	<hr/> SITE ADDRESS <span style="float: right;">CITY                  ZIP</span>
	<hr/> CERTIFIED SITE SUPERVISOR (CSS) <span style="float: right;">CERTIFICATION #</span>
	<hr/> CSS PHONE <span style="float: right;">CSS EMAIL</span>

<b>INSPECTION TASKS</b>		<b>DATE</b> <small>(VERIFIED/COMPLETED)</small>	<b>INITIALS</b>
	1) DDW APPROVED PLANS / ENGINEERING REPORT SIGNATURE	_____	_____
	2) BIOCIDE USED PER ENGINEERING REPORT	_____	_____
	3) DRIFT ELIMINATOR IS INSTALLED PER PLAN	_____	_____
	4) POTABLE WATER SUPPLY (IF PRESENT) HAS AN AIR GAP PER PLAN	_____	_____
	5) RECYCLED WATER SUPPLY HAS AN AIR GAP PER PLAN	_____	_____
	6) COOLING TOWER MODEL NUMBER MATCHES THE ENGINEERING REPORT	_____	_____
	7) PROVIDE COOLING TOWER MANUFACTURER'S NAMEPLATE INFO (SERIAL NUMBER, MANUFACTURING DATE, ETC):		
	<u>COMMENTS:</u>		
	<hr/> INSPECTOR NAME <span style="float: right;">DATE</span>		
	<hr/> RETAILER / SBWR AGENT REPRESENTATIVE <span style="float: right;">DATE</span>		