

STREETLIGHT LEGEND			
LUMINAIRE SYMBOL	LAMP DESIGNATION	LUMINAIRE I.E.S./ANSI LIGHT DISTRIBUTION DESIGNATIONS	LAMP WATTAGE & TYPE
(A) (AP)	SOX 18		18 WATT LPS
(B) (BP)	SOX 35		35 WATT LPS
(C) (CP)	SOX 55	TYPE III, SHORT, NON-CUTOFF	55 WATT LPS
(D) (DP)	SOX 90	TYPE IV, MEDIUM, SEMI-CUTOFF	90 WATT LPS
(E) (EP)	SOX 135	TYPE IV, MEDIUM, SEMI-CUTOFF	135 WATT LPS
(F) (FP)	SOX 180	TYPE IV, MEDIUM, SEMI-CUTOFF	180 WATT LPS
(M) (MP)	LU 50	TYPE III, MEDIUM, SEMI-CUTOFF	50 WATT HPS
(Q) (QP)	LU 70	TYPE III, MEDIUM, SEMI-CUTOFF	70 WATT HPS
(U) (UP)	LU 100	TYPE III, MEDIUM, SEMI-CUTOFF	100 WATT HPS
(V) (VP)	LU 310	TYPE III, MEDIUM, SEMI-CUTOFF	310 WATT HPS
(W) (WP)	LU 150	TYPE III, MEDIUM, SEMI-CUTOFF	150 WATT HPS
(X) (XP)	LU 250	TYPE III, MEDIUM, SEMI-CUTOFF	250 WATT HPS
(Y) (YP)	LU 400	TYPE III, MEDIUM, SEMI-CUTOFF	400 WATT HPS
(Z)	FLUORESCENT		

NOTES:

1. LETTER "P" IN SYMBOL INDICATES THAT A NEMA TWIST-LOCK RECEPTACLE, RATED 15A WITH PHOTOELECTRIC CONTROL DEVICE SHALL BE PROVIDED.
2. ALL BALLASTS SHALL BE OF MULTIPLE VOLTAGE TYPE.
3. ALL HPS LAMPS SHALL BE DESIGNED FOR "BASE DOWN" (BO) OR "ANY POSITION" OPERATION.
4. LU 100 AND LU 150 LAMPS SHALL BE 55V TYPE.
5. BALLAST POWER FACTOR SHALL EXCEED .90.
6. BALLASTS SHALL BE MOUNTED ON TRAY OR ACCESS DOOR.

APPROVED BY

Acw

DATE

3/3/92

STREETLIGHTING LEGEND

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-01b