

NOTES:

1. SEE DRAWINGS E-46 AND E-47 FOR POLE BONDING REQUIREMENTS.
2. 240V CIRCUIT SHOWN. 120V IS SIMILAR EXCEPT USE 1P FUSED CONNECTOR WITH ONE 10A FUSE, IN UNGROUNDED CIRCUIT CONDUCTOR, AND BOND GROUNDED CONDUCTOR TO GROUNDING CONDUCTOR.

APPROVED BY


AWS

DATE

3/3/72

**STREETLIGHT - UNDERGROUND
BRANCH CIRCUIT CONNECTION**

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-08