


TYPE	POLE DATA				ANCHOR BOLT DATA		LUMINAIRE ARM DATA			TRANSFORMER BASE	FOUNDATION TYPE
	A HEIGHT	THICKNESS	MIN. O.D. AT BASE	MIN. O.D. AT TOP	BC BOLT CIRCLE	ANCHOR BOLT SIZE	M PROJECTED LENGTH	P MOUNTING HEIGHT	ARM TYPE		
10A	30'0"	11 GAGE	8"	3.8"	SEE NOTE (3)	1" x 36" x 4"	8'	33'6" ±	C	YES	2
10B	30'0"		8"	3.8"	11"		8'	31'9" ±		NO	2
11A	28'9"	7 GAGE	8"	3.98"	11"		12'	31'9" ±	E	2	

- NOTES:  
 1. USE 10B STANDARD WITH TYPE 'C' ARM UNLESS SPECIFIED OTHERWISE.  
 2. STANDARD FINISH SHALL BE GALVANIZED UNLESS SPECIFIED OTHERWISE.  
 3. SEE DRAWING E-17 FOR TRANSFORMER BASE REQUIREMENTS.  
 4. USE TYPE 2 FOUNDATION WITH 1" x 36" x 4" ANCHOR BOLTS FOR SINGLE/TWIN UNIT LUMINAIRE(S) ON ORNAMENTAL POLES.  
 5. SEE DRAWING E-16 FOR BASE REFERENCES.

APPROVED BY <i>[Signature]</i>	<b>LIGHTING STANDARDS TYPE 10A, 10B AND 11A - OCTAFLUTE</b>		DRAWING NO.
DATE 3/2/92			<b>E-15</b>
<b>DEPARTMENT OF PUBLIC WORKS</b>			