


- NOTES:
1. TERMINATE CONDUIT 1' MIN. - 2" MAX. ABOVE TOP OF FOUNDATION.
 2. FOR TYPICAL SERVICE WIRING DIAGRAM SEE DRAWING E-31.
 3. SEE NOTES DRAWING E-29 & E-30.

APPROVED BY
and
 DATE
 3/3/92

**SERVICE EQUIPMENT
 TYPE III (III M)**

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.
E-28