


13. AN ENGRAVED PHENOLIC NAMEPLATE ON THE DEAD FRONT PANEL INDICATING THE FUNCTION OF EACH CIRCUIT WITHIN THE ENCLOSURE SHALL BE INSTALLED WITH STAINLESS STEEL RIVETS OR STAINLESS STEEL SCREWS:
 - A) ADJACENT TO THE BREAKER OR DEVICE. CHARACTER SIZE SHALL BE A MINIMUM OF 1/8".
 - B) AT TOP OF THE EXTERIOR DOOR PANEL INDICATING SYSTEM NO., VOLTAGE LEVEL, AND NUMBER OF PHASES. CHARACTER SIZE SHALL BE A MINIMUM OF 3/16".
14. THE PLAN SHOWS THE APPROXIMATE LOCATION OF DEVICES WITHIN THE ENCLOSURE. COMPONENTS MAY BE REARRANGED. HOWEVER, THE "WORKING" CLEARANCES WITHIN THE ENCLOSURE SHALL BE MAINTAINED.
15. IN UNPAVED AREAS A RAISED PCC PAD 24" X 3 1/2" X WIDTH OF FOUNDATION SHALL BE PLACED IN FRONT OF NEW SERVICE INSTALLATION. PAD SHALL BE SET TO ELEVATION OF FOUNDATION UNLESS SHOWN OTHERWISE.
16. FOUNDATION SHALL EXTEND 2" MINIMUM BEYOND EDGE OF ENCLOSURE.
17. INTERNAL BUSSING, WHERE SHOWN, IS TYPICAL ONLY. ALTERNATIVE DESIGNS OF PROPOSED SERVICE EQUIPMENT ENCLOSURES SHALL BE SUBMITTED TO THE ENGINEER FOR APPROVAL.
18. CIRCUIT BREAKERS MAY BE MOUNTED IN THE VERTICAL OR HORIZONTAL POSITION.
19. ON TYPE III M SERVICE EQUIPMENT ENCLOSURES, THE METER VIEWING WINDOWS SHALL BE LOCATED ON THE FRONT SIDE OF THE SERVICE EQUIPMENT ENCLOSURE.
20. ALL ANCHOR BOLTS SHALL BE BONDED IN ACCORDANCE WITH DRAWINGS E-83 OR E-84.

APPROVED BY <i>Acad</i>	<p style="text-align: center;">SERVICE EQUIPMENT TYPE III (III M) NOTES - CONTINUED</p>		DRAWING NO. E-30
DATE 3/3/92			DEPARTMENT OF PUBLIC WORKS