



DIMENSION A: 1" MIN., 2" MAX. (TYP. - ALL CONDUITS)  
 " B: 1" MIN., 2" MAX. ABOVE GROUT (TYP. ALL CONDUITS)

NOTES:  
 1. SEE NOTES DRAWINGS E-04, E-05, E-06, AND E-37  
 2. PROVIDE 3' OF SLACK IN ALL CONDUCTORS IN ACCORDANCE WITH SPECIFICATIONS. (SLACK NOT SHOWN).

APPROVED BY  
*Alud*  
 DATE  
 3/3/92

**UNDERGROUND STREETLIGHT SERVICE  
 TYPE IA - 120V**

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.  
**E-33**