

- NOTES:
1. BONDING /GROUNDING DETAIL FOR USE WITH SCH. 40 PVC CONDUIT AND PULL BOX WITHIN 10' FROM POLE.
 2. THE GROUND ROD SHALL BE INSTALLED AT AN OBLIQUE ANGLE NOT TO EXCEED 45 DEGREES FROM THE VERTICAL.
 3. TERMINATE BONDING CONDUCTOR AT POLE GROUNDING LUG WITH UL APPROVED GROUNDING LUG.

APPROVED BY


Ans

DATE

3/3/92

POLE BONDING - METHOD A

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-46