

NOTE:
TIE RODS TO BE INSTALLED IF HYDRANT TEE THRUST BLOCK IS BEARING ON DISTURBED SOIL.


THRUST BLOCK
3 SQ. FT. BEARING
MINIMUM

APPROVED BY
JDM

DATE
4/10/92

**ATTACHED RESIDENTIAL SIDEWALK
FIRE HYDRANT INSTALLATION-
END OF RETURN**

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.
R-14