


CORP. STOP	TYPE 1 & 2	TYPE 3 & 4
FORD	F1100G	F1000G
MUJELLER	H15024	H15006

- NOTES:**
1. TYPE 1-INSTALL ANODE AS SHOWN IN STANDARD DETAIL W-15.
 2. TYPES 1 & 2-WRAP CORPORATION STOP AND 5' OF COPPER TUBING WITH 10 MIL PVC TAPE (1/2" LAPPED).
 3. TYPE 1-IF WATER MAIN IS COATED, REPLACE COATING ON MAIN AND COAT WELD-ON SERVICE SADDLE AND INSULATING BUSHING WITH 1/4" MIN. COATING OF SAME MATERIAL (OR 10 MIL PVC TAPE)
 4. TYPE 2- IF MAIN IS POLYWRAPPED, REPAIR AND EXTEND POLYWRAP TO COVER CORPORATION STOP.
 5. FOR WATER METER INSTALLATION SEE STANDARD DETAIL W-2.
 6. ALL BRASS CORPS FOR BRASS SADDLES SHALL HAVE CC THREADS (SADDLES AND CORPS)

SERVICE CONNECTION SCHEDULE					
SERVICE SIZE	WATER MAIN MATERIAL				
	STEEL	D.I.P.	A.C.P.	R.P.M.	P.V.C.
3/4"	TYPE 1	TYPE 2	TYPE 3	TYPE 3	TYPE 4
1"	"	"	"	"	"
1- 1/2"	"	"	"	"	"
2"	"	"	"	"	"

APPROVED BY <i>WEL</i>	CONNECTION TYPES FOR 3/4" - 2" SERVICE TAPS		DRAWING NO.
DATE <i>4/2/91</i>			W-1
DEPARTMENT OF PUBLIC WORKS			