

NOTES:

1. FOR CONNECTION TO MAIN SEE DETAIL W-1.
2. FOR 1 1/2" AND 2" SERVICES, INSULATE CUSTOMER SERVICE LINE AT BALL VALVE. FOR 1 1/2" SERVICE, INSTALL 2" x 1 1/2" BRASS REDUCER F x M AND 2" x 1 1/2" PLASTIC BUSHING. FOR 2" SERVICE, INSTALL 2 1/2" x 2" BRASS REDUCER FxM AND 2 1/2" x 2" PLASTIC BUSHING.

METER SIZE	METER BOX	ANGLE METER STOP		BALL VALVE		CRITICAL DIMENSIONS	
	CHRISTY	FORD	MUELLER	FORD	MUELLER	A	B
5/8" x 3/4"	B12, B125, B30SL	KV43-332WG	H-14258	NOT REQUIRED	NOT REQUIRED	1" MIN.	2 3/4"
1"	B12, B125, B30SL	KV43-342WG	H-14258	NOT REQUIRED	NOT REQUIRED	1 1/2" MIN.	3"
1 1/2" D	B44, B44E2, B44X4, B44SL	FV43-666WG	H-14277	BF13-666	B20283	1 1/2" MIN.	3 1/4"
2" D	B44, B44E2, B44X4, B44SL	FV43-777WG	H-14277	BF11-777	B20283	2" MIN.	3 3/4"
2" T	B44, B44E2, B44X4, B44SL	FV43-777WG	H-14277	BF11-777	B20283	2" MIN.	2 3/4"

APPROVED BY


usk

DATE

4-2-92

WATER METER SERVICES
3/4" - 2"

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

W-2