



NOTES :

1. MILL TOP OF STEM EXTENSION TO ACCEPT A.W.W.A. WRENCH NUT AND PEEN TOP OF EXTENSION TO SECURE NUT.
2. STEM EXTENSION REQUIRED ONLY WHEN THE DEPTH TO TOP OF VALVE OPERATOR NUT IS GREATER THAN 3'-0".
3. VALVE BOX EXTENSION MAY BE 8" PVC CLASS450 PIPE MATERIAL.

APPROVED BY

[Signature]

DATE

[Signature]

VALVE BOX INSTALLATION

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

W-3