



REDUCER SIZE D1 x D2	ANCHORS FOR REDUCERS	
	250 PSI TEST	200 PSI TEST
	H	H
18" x 12"	3'9"	3'0"
12" x 10"	1'8"	1'4"
12" x 8"	2'6"	2'0"
12" x 6"	2'6"	2'0"
8" x 6"	1'3"	1'0"
8" x 4"	1'3"	1'0"
6" x 4"	1'4"	1'0"

- NOTES:
1. ENCASE ALL BURIED METALLIC SURFACES WITH POLYETHYLENE WRAP AS SPECIFIED IN AWWA C105.
 2. REDUCER ANCHOR IS REQUIRED ONLY WHEN LARGER CONNECTING JOINT IS OTHER THAN FLANGED.

APPROVED BY

[Signature]

DATE

4-27-7

REDUCER ANCHOR BLOCK

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

W-9