



## Accessory Dwelling Units (ADUs) Fire Plan Review: Submittal Intake Checklist

09/05/19 SUBJECT TO CHANGE

**Plans without this information are considered incomplete and will not be accepted for intake.**

San Jose Fire Department (SJFD) will review and enforce applicable California Fire Code (CFC) provisions during the plan review of an ADU. This list does not constitute all requirements for fire department approval. Please consult with Fire Prevention at 408-535-7750 or visit us on the 2<sup>nd</sup> floor of San Jose City Hall (Tower).

**INSTRUCTIONS.** Prior to submitting plans to the building department, please ensure hydrant and water flow data information as indicated below are included with your submittal. Include this completed Submittal Intake Checklist with your plans to the building department.

**INTAKE CHECKLIST.** It is the responsibility of the applicant to check off all required items for intake.

### HYDRANT LOCATION

Provide a site plan. The site plan shall show the location of the nearest fire hydrant(s) serving the project site and the location of the proposed ADU on the lot.

### WATER FLOW DATA

Forward a copy of this "Fire Plan Review: Submittal Intake Checklist" to your water company along with your request for water flow data. See below for a list of water service providers. The data shall show that a minimum flow of 1,000gpm at 20 psi is available from the closest hydrant. Provide a copy of the water flow data along with your submittal.

Need to look up your service provider? <http://www.sanjoseca.gov/index.aspx?nid=3079>

#### San Jose Water Company

Phone: (408) 918-7362

Fax: (408) 279-7889

E-mail: [engineering.dept@sjwater.com](mailto:engineering.dept@sjwater.com)

Please include the words **WATER FLOW** in the subject line and all of the following:

- Requestor's name
- Company name if applicable, company mailing address, phone number and e-mail address
- Street name and address of the project
- Nearest cross street to that location
- A sketch map of where the flow information is requested

#### San Jose Municipal Water System

<http://www.sanjoseca.gov/index.aspx?NID=1579>

Customer Service → Fire Flow Information Request

Phone: 408-277-3671

[muniwatersystem@sanjoseca.gov](mailto:muniwatersystem@sanjoseca.gov)

#### Great Oaks Water Company

Phone: (408) 227-9540

Fax: (408) 227-7126

[customerservice@greatoakswater.com](mailto:customerservice@greatoakswater.com)