

HIGH RISE CHECK LIST				
		CFC	NFPA	Title 19
Fire Alarm				
	Written contract with alarm company for service	907.9		
	Annual test	907.9.2	72	
	Main panel reads "all systems normal"	907.9.5		
	pull stations tested semi-annually	907.9.2		
	exit and emergency lighting monthly test		101	
	fire doors annual testing		92A	
	water flow alarm tested quarterly			
Training				
	annual fire drill report	405.2		
	employee training records	406.3		
	Fire safety and evacuation plan (evacuation, floor plans, exits, assembly points. etc)	404.2		
Standpipe				
	semi annual maintenance and service			
	5 year testing	901.6		art.4
Sprinkler				
	Quarterly maintenance and service	907.9.5		x
	Annual testing	901.6		
	5 year testing	901.6		
Fire Pump				
	Monthly test for diesel and electrical driven system	913.5	25,8.3.1	
	Annual flow test			
Generator		604.4	110,111	
	Weekly inspection	913.5		
	Monthly run test			
Elevator				
	Monthly emergency equipment (recall of FF elevators written record)		9.4.6.2	
Fire Fighter Breathing station				
	Annual testing	901.6		
Alternative fire ext systems				
	Halon	904		
	Dry chemical	904		
	Wet chemical	904		
HMBP				
	MSDS on site	407.2		
	HMBP	2701.5, 2701.5.1, 2701.5.2, 105.6.16		x