

**Grease Interceptor Sizing Form**

The Plumbing Plan Review Section has reviewed the plans for the project shown below and has determined that the grease removal requirements shall comply with the following grease pretreatment device or devices, per the California Plumbing Code and as required by the Building Department, prior to plan review approval or permit issuance.

The sanitary and grease waste piping plans shall be revised as necessary to comply with the pretreatment requirements as indicated on this review document and shall be approved by the County of Santa Clara Department of Environmental Health prior to final approval of Plumbing plans.

All grease retention pretreatment devices shall be listed by a recognized and approved listing agency and shall be installed in accordance with the manufacturer's installation instructions and terms of the listing.

Any deviation from the requirements of this document will require a Variance approval from the Environmental Services Department Regional Wastewater Facility and Watershed Protection section.

**Plan Check #**

**Project Name:**

**Address:**

Plans submitted show the following **Sources of Wastewater:**

_____ Wok Range	_____ Floor Drains	_____ Floor Sinks
_____ Dishwasher	_____ Garbage Grinder	_____ 3-Comp Pot Sinks
_____ Mop Sinks	_____ Hand Sinks	_____ 2-Comp Sinks
_____ _____		

**Pretreatment Requirements:**

Quantity _____	_____ Pound Hydro-Mechanical Grease Trap
Quantity _____	_____ Gallon Gravity Grease Interceptor
Quantity _____	_____ Power Operated Grease Removal Device
	_____ No Requirements

**Grease control device or systems is to be plumbed to accept the wastewater flow from these fixtures:**

_____ Wok Ranges	_____ Floor Drains	_____ Floor Sinks
_____ Dishwasher	_____ Garbage Grinder	_____ 3-Comp Pot Sinks
_____ Mop Sinks	_____ Hand Sinks	_____ 2-Comp Sinks
_____ Other		

**Comments:** Grease Interceptor must be cleaned completely at least every 90 days or when it is 25% full or grease and solids, whichever comes first.

Plan Reviewer:

Date: